CHECK SHEET to consider replacing the equipment or parts

SYSTEM :
Water based local application FFS

This is to recommend timing to consider replacing of the equipment or parts, not mandatory.
The item checked in the box is recommended to replace or keep spare, and the item shown as urgent or important is strongly recommend to replace.
If you have any clarification please feel free to contact us.

No.	Check off if "Yes"	ITEM	LOCATION	CHECK POINT	ACTION	Remarks	Urgency or importance
1		Level switch	Fresh water tank	Function test by test lever	Recommend to replace if the alarm does not work when test lever is operated.		Urgent

Kashiwa Tech Co., Ltd.

●Contact information
KASHIWA TECH CO., LTD. (Tokyo Headquarters)
5-4 Takanawa, 4-Chome Minato-ku, Tokyo 108-0074, JAPAN
Sales department
TEL : +81-3-5449-2431
FAX: +81-3-5449-2430
E-mail: sales@kashiwa-tech.co.jp